



SOUTH DELHI MUNICIPAL CORP
PUBLIC HEALTH DEPARTMENT, WEST ZONE

Vishal Enclave, Rajouri Garden, New Delhi - 110027



Health

No. D-2103/HD/W2

Dated: 22/6/16

Health Certificate


- Name of the school Veda Vyasa D.A.V. Public School
- School address D-Block, Vikaspuri, N. Delhi-18
- No of shifts One Timings: 08.00 AM to 2.00 PM
- No. of students :- Boys 1400
Girls 1052 Total 2452
- No. of staff:- Gents 10 Ladies 131 Total 141

Accommodation provided for classroom as under:-

Floor area in the classroom is sufficient / insufficient sufficient
 Classes are well lighted / ill lighted well lighted
 Classrooms are well ventilated / ill ventilated well ventilated
 Classes are kept / not kept neat and clean neat & clean
 Building / classrooms require / do not require white wash etc. not required
 Drinking water is wholesome / not wholesome DJB water supply
 Latrine arrangement is sanitary / insanitary sanitary

No. of toilets seats for students

Latrine-cum-urinal is required for 25 female students, so total is sufficient
 One latrine for 40 male students is required, so total is sufficient
 Separate toilet arrangement for staff yes/ no Yes
 The overall facilities good / adequate / inadequate adequate



ATTESTED PHOTOGRAPH If Building Department or any other Govt agency takes action against u/a construction or any dispute, then the Health Certificate, will be stand cancelled / revoked without any further intimation in this regard.

Notary Public, Delhi (India)

12 FEB 2020 Shalw
Principal
Veda Vyasa D.A.V. Public School
Vikaspuri, New Delhi-110018

Renewal is not done till date
Dr. RAM SHANKAR
Joint Secretary / Head
Centre of Excellence, Delhi (East)
CBSE, Delhi-110092

Dr.
Dy. Health Officer
Dr. DEEPAK MITTAL
CHOWK, S.D.M.C
Chairman
VEDA VYASA
D.A.V. PUBLIC SCHOOL
Vikas Puri, New Delhi-110 018

23412222
Mr. Atul Singh Bisht

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No: F.6/DFS/MS/School/2015/52 / 1558

Dated: 28/08/15

FIRE SAFETY CERTIFICATE

Certified that the building of Veda Vyasa D.A.V. Public School located at Vikas Puri, New Delhi-110018 having four blocks namely Senior Students Block No-1 (SSB 1), Senior Students Block No-2 (SSB 2), Administrative Block (AB) & Primary Students Block (PSB). The SSB No-1 is comprised of lower ground, ground floor plus three upper floors. SSB No-2, Admn. Block & PSB are comprised of ground floor plus three upper floors. All blocks are interconnect at all level was issued NOC by this department vide letter No.F.6/DFS/MS/2011/1583 dated 15.07.2011. The School building was re- inspected by the officer concerned of this department on 21.08.2015 in the presence of Sh. Rajender Singh Dogra (Admn.) and found that the DAV College Managing Committee have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on 28/08/15 at New Delhi.

(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333



ATTESTED PHOTO COPY

Principal, Delhi
(In-ia)

The Principal,
Veda Vyasa D.A.V. Public School,
Vikas Puri, New Delhi-110018
(Ref. No. VVDAV/VP/15/296 dated 27.07.2015)




2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Principal
Veda Vyasa D.A.V. Public School
Vikasपुरi, New Delhi-110018

Dr. RAM SHANKAR
Joint Secretary / Head
Centre of Excellence, Delhi (East)
CBSE, Delhi-110092

Mr. Sampat
renewal is not done till date
Pl. keep the original file

N.C.V.S.
VEDA VYASA
D.A.V. PUBLIC SCHOOL
Vikas Puri, New Delhi-110 018

		DELHI JAL BOARD (GOVT. OF N.C.T. DELHI)	
		QUALITY CONTROL LABORATORY, WATER TREATMENT PLANT NANGLOI, DELHI-110041	

Water Sample collected from " Veda Vyasa D.A.V Public School" Vikas puri New Delhi Vide Challan No- 144 Dated:- 11-10-2021.

S. No.	Particulars	Units	Limit		S1
			Acceptable	Permissible	
1.	Date of collection	-----	--	--	03.12.2021
2.	Date of Analysis	-----	--	--	05.12.2021
PHYSICAL EXAMINATION					
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	-----	No. Objectionable		No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	0.62
6.	PH value	-----	6.5	8.5	7.2
7.	Electrical Conductivity	µmho	--	--	354
8.	Total dissolved solids	mg/l	500	2000	174
CHEMICAL EXAMINATION					
9.	P th Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/i	200	600	94
11.	Total Hardness	mg/l	200	600	140
12.	Calcium Hardness	mg/l	--	--	88
13.	Magnesium Hardness	mg/l	--	--	52
14.	Calcium as Ca	mg/l	75	200	35.2
15.	Magnesium as Mg	mg/i	30	100	12.48
16.	Ammonia as N	mg/l	0.5	N.R.	NIL
17.	Nitrite as N	mg/l	---	--	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	0.90
19.	Sulphate	mg/l	200	400	32
20.	Chloride	mg/l	250	1000	20
21.	Dissolved Iron	mg/l	0.3	N.R.	0.02
22.	Fluoride	mg/l	1.0	1.5	0.30
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20	1.0	NIL
BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0		0

REMARKS : As per tested parameters sample S1 can be use for drinking purpose.

[Signature]
Chemist 06/11/21

[Signature]
06/12/21
ACWA
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works, Nangloi, Delhi-47