

110024  
11002  
1100  
1100  
1100

Government Approved Licence Agency



# UNITED SALES CORPORATION

**FIRE PROTECTION & SAFETY ENGINEERS**

**SPECIALIST IN : FIRE HYDRANT, SMOKE DETECTION, FIRE ALARM SYSTEM, FIRE & SAFETY AUDIT**

<http://kolhapurhelpline.com/unitedsalescorporation-kolhapur-3.html> • <https://safetyzone.co.in/listing/united-sales-corporation-shahupuri-kolhapur> • <https://www.getcityguide.com/Kolhapur/unitedsales>

Office : 315, 'E', Chandrabhaga, Opp. Hotel Maratha Regency, New Shahupuri, Kolhapur - 416 001 (M.S.),  
Cell : 9823099191, 9822046262, 9823551415 • Ph.:(0231) 2650281 • E-mail : unisalesco@gmail.com

USCO/070

Date: 05-02-2021

## FORM – B

[(See Section 3(3) and rule 4 (2))]

# CERTIFICATE

Certified that we have carried out inspection of the fire prevention and life safety measures installed in the following building / premises

**D.A.V. Public School,**

**(CBSE AFF.NO. 1130067/2003/19341-45)**

**Plot No. 34, Sector 48, Nerul, Navi Mumbai -400706**

We further certify that these installations in above mentioned building are maintained in good repair and efficient conditions during the period **01 July 2020 to 31 Dec 2020** as required under the provisions of the Maharashtra fire prevention and life safety measures Act 2006 (MAH-III of 2007) The details of the inspections of Installations carried out by us are mentioned in the reports appended herewith.

Place : Kolhapur.

Date : 05-02-2021

License No. : MFS-LA/RF-198/RD176



United Sales Corporation

*[Signature]*  
Proprietor

**Safety Consultant :** Reports On Safety Audit, On Site Emergency Plan, Hazop Study, Risk And Consequence Analysis, Building Stability Certificate, Testing of Pressure Vessels, Lifting Tools & Tackles, Approval Of Factory Building As Per Factory Act.

Government Approved Licence Agency

# UNITED SALES CORPORATION

**FIRE PROTECTION & SAFETY ENGINEERS**

**SPECIALIST IN : FIRE HYDRANT, SMOKE DETECTION, FIRE ALARM SYSTEM, FIRE & SAFETY AUDIT**

<http://kolhapurhelpline.com/unitedsalescorporation-kolhapur-3.html> • <https://safelyzone.co.in/listing/united-sales-corporation-shahupuri-kolhapur> • <https://www.getcityguide.com/Kolhapur/unitedsales>

Office : 315, 'E', Chandrabhaga, Opp. Hotel Maratha Regency, New Shahupuri, Kolhapur - 416 001 (M.S.),

Cell : 9823099191, 9822046262, 9823551415 • Ph.:(0231) 2650281 • E-mail : unisalesco@gmail.com

USCO/070

...2...

Date: 05-02-2021

D.A.V. Public School,

(CBSE AFF.NO. 1130067/2003/19341-45)

Plot No. 34, Sector 48, Nerul, Navi Mumbai -400706

Items	Fire Fighting Equipments	Qty.
Riser	Riser 100mm	01 No.
Landing Valve	Landing Valve (Priyanka Make)	07 Nos.
Fire Hose Reel	Hose Reel with Shut of Nozzle ISI Mark (Fabricator)	05 Nos.
Fire Fighting Hose Box	Hose box material M.S. 406 mm X 406 mm with glass, lock & keys	07 Nos.
Fire Hose Pipe	Hose Pipe with Male Female Coupling ISI Mark	07 Nos.
Short Branch Pipe(Nozzle)	Short branch pipe (nozzle) S.S. ISI mark IS:903	07 Nos.
Fire Fighting Tank	Fire Fighting Over Head Tank	01 No.
Fire Fighting Tank	Fire Fighting Underground Tank	01 No.
Courtyard Hydrant	Court Yard Hydrant	02 Nos.
Siamese Connection	Siamese Connection	01 No.
Intel Breaching	Intel Breaching	01 No.



License No. : MFS-LA/RF-198/ RD176

United Sales Corporation

Proprietor

**Safety Consultant :** Reports On Safety Audit, On Site Emergency Plan, Hazop Study, Risk And Consequence Analysis, Building Stability Certificate, Testing of Pressure Vessels, Lifting Tools & Tackles, Approval Of Factory Building As Per Factory Act.

# UNITED SALES CORPORATION

**FIRE PROTECTION & SAFETY ENGINEERS**

**SPECIALIST IN : FIRE HYDRANT, SMOKE DETECTION, FIRE ALARM SYSTEM, FIRE & SAFETY AUDIT**

Office : 315, 'E', Chandrabhaga, Opp. Hotel Maratha Regency, New Shahupuri, Kolhapur - 416 001 (M.S.),  
Cell : 9823099191, 9822046262, 9823551415 • Ph.:(0231) 2650281 • E-mail : unisalesco@gmail.com

USCO/070

...3...

Date: 05-02-2021

**D.A.V. Public School,**

**(CBSE AFF.NO. 1130067/2003/19341-45)**

**Plot No. 34, Sector 48, Nerul, Navi Mumbai -400706**

Items	Fire Fighting Equipments	Qty.
<b>Fire Fighting Pump</b>	Booster Pump (Kirloskar Make)	01 No.
	Electric Pump (Kirloskar Make)	01 No.
	Stand by electric pump (Kirloskar Make)	01 No.
	Jockey pump	Nil
	D.G. Set	01 No.
<b>Alarm System</b>	Alarm System	Yes
	Sprinkler System	Nil
	Smoke Detector (Appllo Make)	07 Nos.
	M.C.P. & Hooter (Appllo Make)	17 Nos.
	Lift	02 Nos.
<b>Fire Extinguishers</b>	1) DCP type(Dry Chemical Powder) 10 Kg Capacity	02 Nos.
	2) DCP type(Dry Chemical Powder) 05 Kg Capacity	05 Nos.
	3) Co2 type Fire Extinguishers 4.5 Kg Capacity	01 No.
	4) Co2 type Fire Extinguishers 03 Kg Capacity	02 Nos.
	5) ABC type fire extinguishers 10 Kg Capacity	Nil
	6) ABC type fire extinguishers 05 Kg Capacity	04 Nos.
	7) Water Co2 type fire extinguishers 5 Ltr Capacity	10 Nos.



United Sales Corporation

Signature & address of the  
Licensed Agency.

License No. : MFS-LA/RF-198/ RD176

Proprietor

**Safety Consultant :** Reports On Safety Audit, On Site Emergency Plan, Hazop Study, Risk And Consequence Analysis, Building Stability Certificate, Testing of Pressure Vessels, Lifting Tools & Tackles, Approval Of Factory Building As Per Factory Act